

ANNEXURE C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No: PH/9/ FHC ADAT

Date: 16.05.2026

It is certified that an inspection team headed by Vincent A.J Health Inspector (Name of officers with designation) from FHC ADAT PHED inspected the Amala Mary Rani Public School, Amalagiri (Name and address of the school) on 16.05.2026 (Date of inspection) and on the basis of Water Test Report attached bearing no KWA/QCDL/TSR/2745/2026 dated 22/4/2026 of Kerala Water Authority (PHEDLab) certified that the Amala Mary Rani Public School (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/U.T. Govt.

This certificate is valid till: 31/03.2027

[Handwritten Signature]

Signature with Seal HEALTH INSPECTOR PHC ADAT

Name: Vincent A.J

Designation: Health Inspector

Name & Address of the Office/Department: FHC Adat



To

Amala Mary Rani Public School, Amala

Thiruvananthapuram

(Name & Address of the Institution)

(Note: The certificate is to be issued by authorized officer/PHED Lab/local bodies)

[Handwritten Signature]
Manager

Amala Mary Rani Public School
Amala Giri, Puranattukara P. O.
Thiruvananthapuram - 680 551



[Handwritten Signature]
PRINCIPAL

AMALA MARY RANI PUBLIC SCHOOL
AMALA GIRI, PURANATTUKARA P.O.,
THIRUVANANTHAPURAM 680 551, KERALA
SCHOOL CODE: 76147

amalamaryranipublicschool2005@gmail.com



QUALITY CONTROL DISTRICT LABORATORY

KIZHAKKUMPATTUKARA THRISSUR

Telephone No - 0487-2338380, E-mail - kwa.qc.tsr@gmail.com

Test Report

Test Report. No :KWA/QCDL/TSR/2745/2026

Report Date:22/04/2026

Customer Name & Address Amala Mary Rani Public School, Amala, Mob: 6238421191		1. Date of receipt :20/04/2026		
		2. Sampling done by : The Customer		
		3. UID No.of Sample: KWA/QCDL/TSR/S-002745/2026		
		4. Source of sample : Openwell		
		5. Sample condition : Fit for requested tests		
		6. Name of sample : Drinking water		
		7. Purpose of test : Commercial		
		8. Sample quantity : 2 litre		
		9. Test performing dates		
		From : 20/04/2026	To:22/04/2026	
Sl. No.	Characteristic	Test Method	Acceptable limit as per IS 10500 - 2012	Result
1	Turbidity, NTU, <i>Max</i>	IS 3025 (part 10) - 2023 Nephelometric method	1	0.37
2	pH at 25°C	IS 3025 (part 11) - 2022 Electrometric method	6.5 to 8.5	6.9
3	Electrical Conductivity at 25°C, microsiemens /cm	IS 3025 (part 14) - 2013 (R. 2023) Electrometric method	-	36.0
4	Total Hardness, (as CaCO ₃), mg/l, <i>Max</i>	IS 3025 (part 21)-2009 (R. 2023) EDTA titration method	200	14.0
5	Chloride (as Cl ⁻), mg/l, <i>Max</i>	IS 3025 (part 32) - 2025 Argentometric titration	250	8.9
6	Iron (as Fe), mg/l, <i>Max</i>	IS 3025 (part 53) - 2024 1,10Phenanthroline method	1.0	0.11
7	Nitrate (as NO ₃), mg/l, <i>Max</i>	APHA 4500 NO ₃ B. Ultraviolet screening method	45	< LOD

Remarks:- All the tested parameters are passed to conform with the acceptable limits of drinking water specification IS-10500:2012

* < LOD - Less than limit of detection

(The statement of conformity(pass/fail) has been evaluated using Simple Acceptance rule, where the measured value is directly compared with the specification limit without applying measurement uncertainty, as the customer has not specified any decision rule)

NB:- The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.




* End of Report *

Reviewed & Authorized By: Ragesh M K

Quality Manager,
Quality Control District Laboratory
KWA Thiruvananthapuram

KWA/QCDL/TSR-R-No:6	Issue No: 3	Issue Date 14.06.2024
Amend.No: 03	Amend Date: 01-12-2025	Page 1 of 1

P. O. K...
Manager
Amala Mary Rani Public School
Amala Giri, Puranattukara P. O.
Thrissur - 680 551



PRINCIPAL
AMALA MARY RANI PUBLIC SCHOOL
AMALA GIRI, PURANATTUKARA P.O.,
THRISSUR 680 551, KERALA
SCHOOL CODE: 76147
✉ amalamaryranipublicschool2005@gmail.com



KERALA WATER AUTHORITY

QUALITY CONTROL DISTRICT LABORATORY

KIZHAKKUMPATTUKARA, THRISSUR

Telephone No - 0487-2338380, E-mail -kwa.qc.tsr@gmail.com

Test Report

Test Report. No :KWA/QCDL/TSR/2745/2026

Report Date : 22/04/2026

Customer Name & Address			1. Date of receipt :20/04/2026	
Amala Mary Rani Public School, Amala, Mob: 6238421191			2. Sampling done by : The Customer	
			3. UID No.of Sample: KWA/QCDL/TSR/S-002745/2026	
			4. Source of sample : Openwell	
			5. Sample condition : Fit for requested tests	
			6. Name of sample : Drinking water	
			7. Purpose of test : Commercial	
			8. Sample Quantity :100ml	
			9. Test Performing Dates	
			From :20/04/2026 To :22/04/2026	
Sl. No.	Parameters	Test Method	Acceptable limits as per-IS 10500-2012	Result
1	Coliform	IS 15185 : 2016 (Reaffirmed 2021)	Shall not be detected / 100ml	< 1 CFU/100ml
2	<i>E.coli</i>	IS 15185 : 2016 (Reaffirmed 2021)	Shall not be detected/ 100ml	< 1 CFU/100ml

Remarks:-Coliform & *E.coli* Bacteria are absent

*CFU- Colony Forming Unit

NB: The results stated above related only to the sample(s) submitted for testing. This test certificate shall not be reproduced except in full without the written approval of the Laboratory.

Reviewed by: **Sruthy P S**
(Microbiologist)



Authorized By: **Jiji K S**
(Microbiologist)

Deputy Quality Manager
Quality Control District Laboratory

* End of Report *

KWA/QCDL/TSR-R-No:6	Issue No:1	Issue Date:01/08/2025
Amend.No: 00	Amend Date: 00	Page 1 of 1

Manager
Amala Mary Rani Public School
Amala Giri, Puranattukara P. O.,
Thrissur - 680 551



PRINCIPAL
AMALA MARY RANI PUBLIC SCHOOL
AMALA GIRI, PURANATTUKARA P.O.,
THRISSUR 680 551, KERALA
SCHOOL CODE: 76147
✉ amalamaryranipublicschool@gmail.com